

UNCLASSIFIED

AD 266 119

*Reproduced
by the*

**ARMED SERVICES TECHNICAL INFORMATION AGENCY
ARLINGTON HALL STATION
ARLINGTON 12, VIRGINIA**



UNCLASSIFIED

NOTICE: When government or other drawings, specifications or other data are used for any purpose other than in connection with a definitely related government procurement operation, the U. S. Government thereby incurs no responsibility, nor any obligation whatsoever; and the fact that the Government may have formulated, furnished, or in any way supplied the said drawings, specifications, or other data is not to be regarded by implication or otherwise as in any manner licensing the holder or any other person or corporation, or conveying any rights or permission to manufacture, use or sell any patented invention that may in any way be related thereto.

266119

AF/SSD-TR-61-4

R-3132

MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE

CATALOGED AS ASTIA

AS AD NO.

266 119

ROCKETDYNE

A DIVISION OF NORTH AMERICAN AVIATION, INC.
6633 CANOGA AVENUE, CANOGA PARK, CALIFORNIA

CONTRACT AF33 (616)-6939


PROJECT No. 3148

TASK No. 30196

SEPTEMBER 1961

XEROX

6-2-1-3



ROCKET TEST ANNEX
SPACE SYSTEMS DIVISION
AIR FORCE SYSTEMS COMMAND
UNITED STATES AIR FORCE
EDWARDS AIR FORCE BASE, CALIFORNIA

AF/SSD-TR-61-4

R-3132

MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL
FOR CHLORINE TRIFLUORIDE

Rocketdyne

A Division of North American Aviation, Inc.
6633 Canoga Avenue, Canoga Park, California

Contract AF33(616)-6939

Project No. 3148

Task No. 30196

September 1961

ROCKET TEST ANNEX
SPACE SYSTEMS DIVISION
AIR FORCE SYSTEMS COMMAND
UNITED STATES AIR FORCE
EDWARDS AIR FORCE BASE, CALIFORNIA

FOREWORD

This manual is one of a group of four design-criteria manuals prepared under Contract AF33(616)-6939, Supplement 1, PN 3148, TN 30196. The administrative and technical direction of this effort was provided by Messrs. F. S. Forbes, J. Marshall, and J. H. Smith of the AFFTC, Edwards Air Force Base, California. The manuals were prepared by the Analysis and Equipment Group of the Rocketdyne Engineering Department, and the Rocketdyne Facilities Engineering Department.

The design-criteria manuals were titled and identified as follows:

AF/SSD-TR-61-6	Mechanical System Design-Criteria Manual for Hydrazine
AF/SSD-TR-61-5	Mechanical System Design-Criteria Manual for Nitrogen Tetroxide
AF/SSD-TR-61-4	Mechanical System Design-Criteria Manual for Chlorine Trifluoride
AF/SSD-TR-61-3	Mechanical System Design-Criteria Manual for Pentaborane

A group of four propellant handling manuals were also prepared under Contract AF33(616)-6939, Supplement 1, PN 3148, TN 30196. These manuals were titled and identified as follows:

AF/SSD-TR-61-7	Hydrazine Handling Manual
AF/SSD-TR-61-8	Nitrogen Tetroxide Handling Manual
AF/SSD-TR-61-9	Chlorine Trifluoride Handling Manual
AF/SSD-TR-61-10	Pentaborane Handling Manual

ABSTRACT

This manual presents criteria for the design and fabrication of a chlorine trifluoride storage facility. Primary consideration is given to the integrity of the storage system, and personnel safety.

The properties of chlorine trifluoride affecting the selection, design, and fabrication of storage facilities are described and discussed.

The selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with chlorine trifluoride are discussed.

(Unclassified Abstract)

CONTENTS

Foreword	iii
Abstract	iv
Introduction	1
1.0 Properties of Chlorine Trifluoride	3
1.1 General Properties	3
1.2 Physicochemical Properties	3
1.3 Toxicity	4
1.4 Flammability and Reactivity	8
2.0 Site Selection	9
2.1 General	9
2.2 Meteorological Considerations	9
2.3 Quantity-Distance	10
2.4 References	11
3.0 Storage Area	12
3.1 General	12
3.2 Meteorological Concepts	12
3.3 Layout and Orientation	14
3.4 Propellant Storage and Transfer System	15
3.5 Diking and Retainment	21
3.6 Safety and Fire Protection	22
3.7 Disposal	23
3.8 Electrical Concepts	24
3.9 References	25
4.0 Materials Selection	26
4.1 General	26
4.2 Compatible Materials	26
4.3 Materials Suitable for Limited Service	28
4.4 Unsuitable Materials	29

4.5	Additional Compatibility Behavior	29
4.6	References	30
5.0	Equipment Design and Selection	31
5.1	General	31
5.2	Vessels	32
5.3	Piping Systems	32
5.4	Stainless-Steel Tubing and Fittings	39
5.5	Valves	40
5.6	Relief Devices	43
5.7	Regulators	44
5.8	Pumps	45
5.9	Filters	45
5.10	Air Pollution Monitoring	46
5.11	Liquid Level Indicators	46
5.12	References	47
6.0	System Fabrication	49
6.1	General	49
6.2	Welding	49
6.3	Brazing and Soldering	51
6.4	Mechanical Joints	51
6.5	Inspection	53
6.6	References	55
7.0	Hydrostatic and/or Pneumatic Tests	57
7.1	Storage Vessels	57
7.2	Valves, Piping, and Fittings	59
7.3	Applicable Codes and Specifications	60
8.0	Cleaning Procedures	61
8.1	General	61
8.2	Degreasing	62
8.3	Descaling or Cleaning	63
8.4	Passivation	64

8.5	Propellant Passivation	65
8.6	Drying and Handling	66
8.7	Inspection	67
8.8	Material Reference	68
9.0	Inspection and Maintenance	69
9.1	General	69
9.2	Inspection	69
9.3	Maintenance	71
10.0	Reactivation of Existing Facilities	73
10.1	Design Evaluation	73
10.2	Inspection of Usable Components	73
10.3	Rework and/or Cleaning of Usable Components	73
11.0	Appendices	75
11.1	Water Storage Capacity	75
11.2	Acceptance Standards for Welds	75
11.3	Specifications Criteria for the Design and Fabrication of Facility Installations	77

ILLUSTRATIONS

1. Viscosity vs Temperature for Chlorine Trifluoride	5
2. Vapor Pressure vs Temperature for Chlorine Trifluoride . . .	6
3. Density vs Temperature for Liquid Chlorine Trifluoride . . .	7
4. Schematic Representation of a Typical Chlorine Tri- fluoride Storage Tank System	17
5. Schematic Representation of a Typical Installation for Unloading Chlorine Trifluoride Cylinders	19
6. Gallons per Minute vs Change in Pressure for Chlorine Trifluoride at 25 C	34

INTRODUCTION

This manual presents criteria for the design and fabrication of a chlorine trifluoride storage facility. These criteria have been derived from a comprehensive survey of current literature, and information accumulated by several contractors. Consideration is given to the establishment of facilities capable of handling propellant flow-rates of up to 10,000 gpm, operating pressures of up to 3000 psi, and for propellant storage quantities as large as 5,000,000 pounds.

The advent of the use of high-energy propellants had introduced a need for storage and handling criteria for these propellants. The more conventional propellants such as liquid oxygen and hydrocarbon fuels, are considered to be hazardous, but generally the hazard is limited to flammability. With most high-energy propellants, flammability is only a small portion of the handling and storage problem. Other important considerations arise from the unique chemical and physical properties of these propellants such as:

1. Spontaneous reaction with air or other propellants (pyrophoricity, hypergolicity, etc.)
2. Chemical attack on common materials of construction
3. Formation of explosive mixtures with air or other chemicals
4. Toxicity

Because of these unique characteristics, it is essential that the designer of propellant systems be thoroughly familiar with the problem areas associated with each high-energy propellant--chlorine trifluoride is no exception.

The information presented in this manual is divided into 11 sections. Each section contains information dealing with a specific subject such as materials selection, cleaning procedures, etc. Some of the information presented, such as quantity-distance values, is subject to revision in the near future.

1.0 PROPERTIES OF CHLORINE TRIFLUORIDE

1.1 General Properties

Chlorine trifluoride (CTF) is a nearly colorless gas at normal atmospheric temperature and pressure. In its liquid state, chlorine trifluoride is a very pale green-yellow. The solid state is white. The odor of chlorine trifluoride has been described both as sweet and pungent, similar to chlorine or mustard. Chlorine trifluoride is a toxic and corrosive oxidizing agent, similar to elemental fluorine in nature. It is soluble in all proportions in liquid chlorine and in liquid anhydrous hydrogen fluoride. Commercial chlorine trifluoride is over 99-percent ClF_3 . The most likely trace impurity is hydrogen fluoride. At 500 F, chlorine trifluoride disassociates presumably into fluorine and chlorine monofluoride, to the extent of about 1 percent.

1.2 Physicochemical Properties

Formula	ClF_3
Molecular Weight	92.46
Boiling Point (atmos. pressure)	53.15 F
Freezing Point	-105.38 F
Specific Gravity	1.85 at B.P.
Density, lb/cu ft	115.49 at B.P.
Vapor Pressure, psia	17.2 at 60 F 39.7 at 100 F 80.6 at 140 F
Viscosity, $\text{lb}_m/\text{ft-sec}$	3.21×10^{-4} at B.P.
Coefficient of Thermal Expansion	0.000867/F, from 23 to 115 F

Compressibility Factor,	
Gaseous CTF at 1 atmosphere	0.968
Surface Tension, lb _f /ft	0.00170 at B.P.
Critical State Data	307 F.
	837.7 psia
Heat of Formation, Btu/lb-mol	80,100 at 55.4 F
Heat of Fusion, Btu/lb	35.4 at -103.3 F
Heat of Vaporization, Btu/lb	128.1 at 53.15 F
Heat Capacity, Btu/lb-F	0.303 at 41.16 F

Included for additional information on the physicochemical properties are Fig. 1, 2, and 3, giving viscosity, vapor pressure, and liquid density, respectively, as a function of temperature.

1.3 Toxicity

Chlorine trifluoride must be considered a highly toxic material; however, by use of proper handling techniques and equipment, it can be safely handled. It is approximately ten times as toxic as chlorine. A maximum allowable concentration of chlorine trifluoride in air of 0.1 ppm was established by the American Conference of Governmental and Industrial Hygienists.

Other authorities have suggested a maximum allowable concentration of 3 ppm for repetitive 8-hour day exposures. Concentrations of 50 ppm may be fatal for exposures over 15 minutes. In concentrations of over 100 ppm, symptoms of toxic attack are noted in 3 minutes. However, fatal concentrations are so irritating to the eyes and respiratory system that the area is intolerable. The threshold of perception is very low (approximately 0.1 to 0.2 ppm) and, since the vapors are so noxious, a




Figure 1. Viscosity vs Temperature
for Chlorine Trifluoride




Figure 2. Vapor Pressure vs Temperature
for Chlorine Trifluoride




Figure 3. Density vs Temperature for
Liquid Chlorine Trifluoride

contaminated area is usually evacuated before dangerous exposure. With proper equipment and handling by trained personnel, chlorine trifluoride may be safely handled, stored, and transferred with a minimum of danger to equipment or personnel.

1.4 Flammability and Reactivity

Chlorine trifluoride is a vigorous oxidizer that will support combustion with almost all organic vapors and liquids and will react explosively with water and ice. With the exception of elemental fluorine, chlorine trifluoride is one of the most reactive chemical substances known. At elevated temperatures, it will ignite many common metals. It is, in itself, insensitive to shock and electrical spark and is nonflammable with air.

2.0 SITE SELECTION

2.1 General

Desert, mountain, or off-shore island sites are most favorable for a chlorine trifluoride storage facility. The desert sites are characterized by barren wasteland, strong surface winds, strong uplifting thermal currents and low humidity. The population density of such an area is usually extremely low and pollution of off-site public ground waters can be easily controlled. The cost of sufficient real estate which is located downwind is usually low enough to permit its purchase or control so that air pollution will not be a problem. The scarcity of water in such sites may force recovery, simultaneously reducing the water pollution problem. Mountain sites usually possess consistent wind direction, extended wind duration, dispersive terrain, good soil stabilization, natural blast and noise barriers, good hydraulic gradients, and water availability. Pollution of off-site public ground waters may be possible at mountain sites; however, the height of release of vapors from spillages of chlorine trifluoride will likely reduce the downwind air pollution hazard. Off-shore island sites present the following advantages: intervening unpopulated areas, consistent wind direction, ideal drainage and disposal of contaminated propellant and waters. A decided disadvantage is the lack of over-land communications and transportation.

2.2 Meteorological Considerations

All atmospheric dispersal equations indicate that the ground level concentration of gases or smokes in air are inversely proportional to the square of the height of release above an aerodynamically

smooth plain if release is continuous, and inversely proportional to the cube of the height of release, if release is instantaneous (Ref. 2.4.1). Thus, storage areas should be located at the highest accessible elevations in such orientation that the prevailing wind in that area will carry vapors from spillage toward unpopulated areas or over the top of a ridge which elevates the effective height of release.

2.3 Quantity-Distance

Due to its high vapor pressure at ambient temperatures, chlorine trifluoride storage and transfer presents an ever-present toxic hazard to downwind areas. Criteria for the specific location of the site in relation to surrounding habitation and public transportation is given in Ref. 2.4.2 (T0 11C-1-6). The quantity-distance table (Table 1) was extracted from this reference. This table gives the limiting values for a Class A, poisonous substance of Group 11.

TABLE 1

Quantity of Group 11 Propellants		Barricaded Distance in Feet to				Unbarricaded dist. in ft to
Pounds over	Pounds not over	Inhabited Building Service Bldg +	Passenger Railroad*	Public H'way*	Magazine or other Group 11, Stge. (Z)	Magazine or other Group 11 Storage
10	1,000	5,000	305	155	100	200
1,000	5,000	5,000	450	225	150	300
5,000	10,000	10,000	520	260	200	300
10,000	50,000	10,000	840	420	200	400
50,000	100,000	10,000	1,090	545	400	500
100,000	250,000	10,000	1,295	650	500	800

*American Table of Distances. Double these if storages are Unbarricaded.

+For distances from Storages (except ready storages) to Operating Bldg. use (Z) Inhabited Building distances.

2.4 References

2.4.1 Meteorology and Atomic Energy, AECU 3066, July 1955.

2.4.2 General Safety Procedures for Chemical Guided Missile Propellants
T0 - 11C-1-6, 12 December 1956.

3.0 STORAGE AREA

3.1 General

A chlorine trifluoride-bearing facility may exist in the form of: (1) a singular area for the storage of chlorine trifluoride only; (2) a common singular area for the storage of chlorine trifluoride and other oxidizers; (3) an area complex for the storage of chlorine trifluoride and other oxidizers; and (4) an area complex for the storage of chlorine trifluoride and other propellants, including fuels. In addition, the facility may be located in an isolated area, or in the proximity of a test or launch installation.

The design criteria for each particular form of chlorine trifluoride-bearing facility must be considered independently. This is necessary because each propellant in the facility requires special consideration. In addition, a facility located in the proximity of a launch or test installation, for example, is exposed to vibrational and thermal effects, which also require special consideration.

The design criteria presented herein pertains mainly to the design of a singular, basic facility for the storage of chlorine trifluoride only. Such a facility will be referred to as a chlorine trifluoride storage area, or simply, a storage area. The propellant is assumed to arrive at the storage area in one-ton-capacity cylinders.

3.2 Meteorological Concepts

The concept of establishing meteorological monitoring of activities capable of discharging toxic effluents into the atmosphere is well

accepted. The precise nature of these activities, and the environment in which they are performed, determines the extent of meteorological control required.

Considering a storage and test complex as an entity, the contribution of the meteorologist is of the greatest importance in the planning and site selection phases. Working with the facility engineers, he must achieve a design and location which would guarantee that any release of toxic gases resulting from an accidental propellant spill of any conceivable magnitude would be reduced to relatively harmless concentrations by the time it reaches off-site population. These design and location criteria must be valid for the worst probable meteorological conditions.

It is obvious that when these protective criteria have been realized, there are no normal operational activities at a storage and test complex which could constitute any greater off-site hazard. In effect, this indicates that meteorological control is not required at the storage and test complex for the protection of off-site population.

To afford the maximum protection to operating personnel on or near the site, additional measures must be taken. Personnel exposure to toxic gases is minimized not only by proper and judicious use of safety clothing and breathing equipment, but also by:

1. The use of detection equipment in conjunction with alarm systems to warn of accidental releases
2. The performance of transfer and disposal operations under specifications established by competent meteorologists.

These specifications are dependent, for the most part, upon the specific orientation of buildings, roads and offices, and would establish, primarily, the proper wind directions, wind speeds and times of day for safe operation

It is recognized that no storage area would be completely independent, but that it would exist in conjunction with either a rocket launch or test installation. It is at the latter facilities, where the probability of massive toxic releases is so high, that a Meteorological Control Center would exist. The minor meteorological effort required for a storage area should be directed by this central control office.

Meteorological instrumentation required for a storage and test complex is basic, consisting of wind direction and speed transducers connected to recorders and hygrothermographs located in weather instrument shelters. The number and location of these instruments is a function of facility size and topography and is determined by the meteorologist as part of his site analysis.

3.3 Layout and Orientation

The storage area should be oriented so that the prevailing winds do not carry vent gas, vapor from leaks and spills, or vapor from disposal and treatment areas into work and service areas, parking areas, or roads carrying heavy traffic.

The storage area arrangement and layout shall be in accordance with Para. 5 of Ref. 3.9.1. Provisions must be made to include not only the necessary equipment and facilities, but also for possible expansion. The storage area should be properly fenced.

3.4 Propellant Storage and Transfer Systems

3.4.1 Storage Tanks

Chlorine trifluoride can be stored in either the one-ton-capacity shipping cylinders or in larger storage tanks. The cylinders can be stored in groups of four and treated, for facility design purposes, as a storage tank. Provisions should be made to unload each group of cylinders simultaneously.

Storage tanks and associated piping should be designed and fabricated as per Sections 5.0 and 6.0 of this document. The materials of construction should be selected for compatibility with chlorine trifluoride per Section 4.0.

The storage tanks should be sized to receive several individual shipments, with at least 10-percent volumetric allowance for ullage. A nominal tank capacity of 2000 gallons is recommended. All storage tanks and associated valves and piping should be located above ground to facilitate the detection of leaks. Tank supports and foundations should be designed with a minimum safety factor of 4, with due regard for local seismic and vibrational conditions. Each tank should be located within a separate retaining wall, dike, or revetment, sized to contain at least 1-1/2 times the tank capacity. Each tank should be electrically grounded and equipped with an adequately sized, remotely controlled, "fail-safe" vent valve. Storage tanks may be located as close as 8 feet to each other, provided that adequate water spray coverage is available. All main tank connections should be made through the top portion of the tanks to reduce the possibilities of propellant spill.

A well must be provided at the bottom of the storage tanks to permit almost complete propellant drainage. The well may, in turn, be completely drained for cleaning purposes by providing an adequate tank connection.

A schematic presentation of a storage tank system is shown in Fig. 4. This system reflects most the criteria presented above. The identification of the various test components is as follows:

<u>Component No.</u>	<u>Description</u>
1	Valve, dike drain
2	Valve, tank well drain
3	Dike
4	Storage tank
5	Dip tube
6	Filter, product discharge
7	Valve, pump shutoff
8	Pump, transfer
9	Valve, tank product discharge shutoff
10	Valve, tank vent shutoff
11	Valve, discharge line purge
12	Valve, tank fill shutoff
13	Filter, tank fill
14	Valve, tank fill isolation
15	Valve, regulated gaseous nitrogen shutoff
16	Gage, regulated gaseous nitrogen pressure
17	Regulator, gaseous nitrogen pressure
18	Filter, gaseous nitrogen




Figure 4. Schematic Representation of a Typical Chlorine Trifluoride Storage Tank System

<u>Component No.</u>	<u>Description</u>
19	Valve, high-pressure gaseous nitrogen shutoff
20	Valve, tank vent
21	Valve, burst diaphragm shutoff
22	Diaphragm, burst
23	Valve, flow check
24	Valve, sight gage isolation
25	Gage, level indicator
26	Valve, sight gage isolation
27	Transducer, temperature
28	Valve, pressure sensing line shutoff
29	Gage, tank pressure
30	Transducer, pressure

A schematic representation of a cylinder unloading installation is shown in Fig. 5. The identification of the various components is as follows:

<u>Component No.</u>	<u>Description</u>
1	Valve, product discharge shutoff
2	Filter, product discharge
3	Valve, product discharge isolation
4	Valve, discharge line purge
5	Valve, cylinder discharge shutoff
6	Valve, cylinder inlet shutoff
7	Valve, gaseous nitrogen shutoff




Figure 5. Schematic Representation of a Typical Installation for Unloading Chlorine Trifluoride Cylinders

<u>Component No.</u>	<u>Description</u>
8	Cylinder, shipping
9	Valve, vent
10	Diaphragm, burst
11	Valve, burst diaphragm shutoff
12	Gage, regulated gaseous nitrogen pressure
13	Regulator, gaseous nitrogen pressure
14	Filter, gaseous nitrogen
15	Valve, high-pressure gaseous nitrogen shutoff

3.4.2 Transfer Systems

Propellant transfer systems should be arranged and connected to permit safe and systematic transfer of chlorine trifluoride without loss or contamination. Pumps, valves, and lines should be sized to provide efficient transfer without excessive pressure loss. Materials of construction and fabrication methods, coupled with cleaning procedures, should be adequate for extended service in chlorine trifluoride. System components should be adequately and rigidly supported with due allowance for temperature changes. The possibility of propellant leakage can be significantly reduced by using all-welded pipe lines with flanged end connections. System components should be located within the diked area to facilitate spillage control. The inlet and discharge terminals of transfer lines should be valved. The transfer lines should be designed and installed to provide for adequate liquid drainage and purging.

The tank vent lines should be piped into a gas scrubber or a high vent stack. If a vent stack is used, the effluent vapor should be released at least 60 feet from the highest working point in the area.

Chlorine trifluoride can be unloaded from the storage tanks by means of a transfer pump or by pressurizing the tank with gaseous nitrogen. The use of a transfer pump is preferred because: (1) it reduces the gaseous nitrogen storage requirements, (2) electrical power is readily available, (3) large quantities of the propellant can be transferred in a relatively short period of time, and (4) lighter storage tanks can be fabricated. For such applications, a reliable flange-mounted, submerged pump offers merit since it requires no priming, is easily installed, and causes no external leakage.

The use of gas pressurization is recommended for unloading the chlorine trifluoride shipping cylinders. The gas pressurization technique should not be completely disregarded for possible use in unloading the large storage tanks. It offers considerable advantages such as reliability, simplicity, and ease of operation and maintenance. In addition, since gaseous nitrogen is required at the storage area for pressurization, purging, and blanketing, a separate gaseous nitrogen storage system is not required.

5.5 Diking and Retainment

Each chlorine trifluoride storage tank shall be installed within a separate dike, revetment, or walled area to retain spilled propellant. This containment should have a smooth, impervious, and

acid-resistant cement lining. The dike or retainment should be capable of retaining at least 1-1/2 times the tank capacity. The diking system should be designed so that it will gravity-drain into a burn basin, a collection basin, and a reclamation sump. These facilities can be interconnected by means of acid-resistant channels and isolated as required by means of valves.

3.6 Safety and Fire Protection

Chlorine trifluoride fires can be controlled by spraying the fire with copious quantities of water. In this instance, the water is effective only in cooling the surrounding equipment. A fog-nozzle type spraying system is particularly suitable for this application. Water sprays are of value also in controlling chlorine trifluoride spills and in removing residual hydrofluoric acid and other fluorides following a propellant spill or fire.

The chlorine trifluoride storage area should be provided with a fire-water loop system of ample and adequate size with strategically located hydrants. A water spraying system must be included to provide remote-controlled water coverage to the storage tanks and cylinders. An adequate supply of water for fire fighting and washdown is imperative. Provisions should be made for replenishment of the total stored water within twelve hours, or less, without the use of portable or emergency equipment. Water may be either fresh, brackish, treated and recovered, or salt water.

The determination of the water storage capacity required at the chlorine trifluoride storage area is discussed in Sect. 11.0. Sufficient water storage capacity should be available to dilute the contents of at least one storage tank to very low hydrofluoric

acid concentration, with a generous allowance for evaporation and spillage, and still leave a reserve capacity for cooling other storage tanks and systems and for personnel safety purposes.

Water spraying systems should be protected from freezing in locations where temperatures may fall below 32 F. The spraying system should be fabricated of pipe not less than one inch in diameter and provided with a nozzle pressure of at least 50 psig.

The storage area should be provided with portable, chemical-type fire extinguishers. The carbon dioxide extinguisher is recommended for general use throughout the area.

The storage area should be provided also with a generous amount of strategically located safety equipment. This equipment should consist of safety showers, eyewash fountains, and fire blankets. Facilities must be available for the storage of personnel safety equipment.

The storage area should be fenced and equipped with appropriate warning signs, safety placards, and other equipment and techniques typical of good industrial practice.

3.7 Disposal

The chlorine trifluoride storage area must be provided with facilities for the safe disposal of chlorine trifluoride and contaminated solutions. Chlorine trifluoride disposal can be accomplished by burning or reacting. The burning operations can be performed in a rectangular, flat-bed type burn basin. A

collection basin can be utilized for the reaction technique. The burn and collection basins should have a smooth, impervious and acid-resistant cement or metal lining.

Chlorine trifluoride can be disposed of efficiently by burning the propellant with a fuel such as kerosene or alcohol. The propellant can be disposed of also by reacting with water, calcium carbonate, or any alkali solution. The reaction with water yields hydrofluoric acid which can be disposed of by reacting with an alkali solution. When the hydrofluoric acid concentration in the collection basin falls below that locally permitted, the contents of the basin should be drained into the reclamation sump.

3.8 Electrical Concepts

All electrical installations throughout the storage area shall conform to the national, state, and local codes for the type of area and service involved. The area shall be floodlighted in accordance with good industrial and safety practices for the type of work involved. Electrical power distribution within the storage area shall be made through appropriate ducts, preferably underground. Adequate electrical receptacles shall be strategically located for maintenance purposes.

All vent stacks, storage tanks, and steel structures shall have integrally mounted lightning protection systems in accordance with Sect. 8 of Ref. 3.9.2. All storage tanks, pumps, loading points, electrical equipment, and propellant transfer lines shall be grounded and bonded electrically, in accordance with national, state, and local codes.

3.9 References

- 3.9.1 General Safety Procedures for Chemical Guided Missiles Propellants, T.O. 11C-1-6, 1956.
- 3.9.2 Ordnance Safety Manual, ORD M7-224 (T.O. 11A-1-40C).

4.0 MATERIALS SELECTION

4.1 General

The following lists of materials and their behavior when exposed to chlorine trifluoride are the result of studies by Rocketdyne and others, and are based upon laboratory exposures under closely controlled conditions and experiences in field use (Ref. 4.6.1-4.6.5).

Although chlorine trifluoride is extremely reactive, it does not attack compact metals such as copper, brass, Monel, or nickel due to the formation of a passive metal fluoride film. The corrosive resistance of all materials of construction used with chlorine trifluoride depends upon the formation of this passive film. Therefore, before any equipment, piping, and vessels are placed in service, they must be thoroughly cleaned and propellant passivated in accordance with Section 8.0.

4.2 Compatible Materials

The following materials have been found suitable for use with chlorine trifluoride.

<u>Structural Application</u>	<u>Liquid CTF</u>	<u>Gaseous CTF</u>
Exhaust gas neutralizer and/or burnoff stacks		Mild Steel
Gaskets	Aluminum 1100 Lead Indium Alloy Copper Copper Laminated Stainless Steel 303 Sterling Silver	Aluminum 1100 Lead Indium Alloy Copper Teflon Tin

Structural ApplicationLiquid CTFGaseous CTF

Lines and Fittings

AlSI 300 Series
Stainless Steels
Nickel
Monel
Inconel
Aluminum 1160
Aluminum 6063
Aluminum 3003
Aluminum 2024
Aluminum 5052
Aluminum 6061
Aluminum 6066
Copper

Same as Liquid

Lubricants

None

None

Orifice-Meter

K-Monel

Pump Materials
(Volute, Impeller and Shaft)Aluminum 356
Aluminum Tens 50
Aluminum 6061
Aluminum 6066
Rene Nickel 41
Tin
Carbon
MonelAluminum 356
Aluminum Tens 50
Tin
Boron Carbide
Carbon

Rotating Seals

Tin Indium Alloy
Copper
Tin
Indium
Silver Solder
Boron Carbide
Carbon

Same as Liquid

Wear Plates

Rene Nickel 41
Stainless Steel
Stainless Steel 347
Nitralloy
Chromium Plated Steel

Same as Liquid

Bearings

Aluminum
Copper
Bronze

Same as Liquid

<u>Structural Application</u>	<u>Liquid CTF</u>	<u>Gaseous CTF</u>
Valve Bellows (Packless valves)	Stainless Steel 321 Stainless Steel 347 Monel Aluminum	Same as Liquid
Valve Bodies	Most 18-8 Stainless Steels Bronze K-Monel Aluminum Casting Alloys Aluminum Tens 50 Aluminum 356	Same as Liquid
Valve Packing	Teflon-Chevron	Teflon-Chevron Copper-laminated Teflon
Valve Plugs	Stainless Steel 304 Stainless Steel 321 Stainless Steel 347 K-Monel Inconel	Same as Liquid
Valve Seats	Copper Aluminum 1100	Copper Aluminum 1100
Tanks	Same materials as for liner and fittings	Same as Liquid

4.3 Materials Suitable for Limited Service

Chlorine trifluoride will occasionally "ignite" fluorocarbon polymers, therefore each Teflon gasket should be exposed to chlorine trifluoride prior to its use to prove compatibility. No point on the exposed Teflon gasket or sealing surface should be more than 0.002 to 0.003 inches removed from the metal heat conductor. It does not react with Pyrex glass, but will attack it via HF upon exposure to moisture.

4.4 Unsuitable Materials

The following are known to be unsuitable for use in chlorine trifluoride systems:

- Titanium
- Columbium
- Molybdenum
- Graphite with plastic binders
- Carbon with plastic binders
- Polyethylene
- Saran
- Nylon
- Rubber (Buna and Butyl)
- Neoprene
- Glass and glassed steel
- Silicones and fluorosilicones
- KoroSeal
- Viton-A
- Hydrocarbon or Ester base lubricants
- Glyptal sealants
- Epoxy sealants

4.5 Additional Compatibility Behavior

Fluoride deposits accumulate on stainless-steel components after prolonged exposure with chlorine trifluoride. The corrosion product consists primarily of hydrolyzed fluoride salts of iron, chromium, and nickel. Of the 300 series stainless steels, 304 gives superior service. Types 303, 321, and

347 stainless steel has greater corrosion buildup due to the reaction with impurities that are trapped in inclusions in these steels. The presence of moisture in a chlorine trifluoride system accelerates corrosion (hydrolyzed fluoride salts), and will cause embrittlement of the protective fluoride film. Mechanical shock can cause separation of this coating and expose unpassivated surfaces to chlorine trifluoride. Clad steels are unreliable for use with chlorine trifluoride because of difficulty in assuring continuity and quality of welds.

4.6 References

- 4.6.1 "Chlorine Trifluoride (CTF) and other Halogen Fluorides", Technical Bulletin TA-8532-2 published by General Chemical Division of Allied Chemical.
- 4.6.2 "Investigation of Liquid Rocket Propellants," by M. R. Hull and others, Aerojet Engineering Corporation, 25 January 1960, CONFIDENTIAL.
- 4.6.3 "Investigation of Liquid Rocket Propellants, by C. L. Randolph and others, Aerojet Engineering Corp., January 1951, CONFIDENTIAL.
- 4.6.4 Chlorine Trifluoride, Properties and Method of Handling, Manual CT-1, Pennsylvania Salt Manufacturing Co., 1952.
- 4.6.5 Report on Chlorine Trifluoride, U. S. Army Chemical Corp. Medical Laboratories Report MLCR No. 12, 15 September 1952.

5.0 EQUIPMENT DESIGN AND SELECTION

5.1 General

The list of reference material included is a compilation of readily available data to facilitate the design and specification of systems handling chlorine trifluoride. Manufacturers listed herein are typical only for the type of product; the list does not restrict the field to those mentioned, or eliminate those not mentioned.

In the design of systems for use with reactive materials, special care must be taken in the selection of pressure relief and vent systems (Ref. 5.12.20).

All systems should include suitable filters to filter chlorine trifluoride and purge or pressurize gas before entering the systems. All purge, pressurizing, and inert blanket gas should be dehumidified to a dewpoint of -65 F or lower.

Due to the constant hazard of fluoride particles in chlorine trifluoride, all streams of propellant should be filtered.

Piping and vessel systems should be electrically bonded and grounded so that the maximum resistance from flange to flange shall not exceed 10 milliohms and the resistance from any part to ground shall not exceed 25 milliohms.

Since chlorine trifluoride is extremely corrosive and toxic, all equipment and systems must have a high degree of integrity, and positive sealing characteristics.

5.2 Vessels

All pressure vessels for propellant storage should be designed and constructed in accordance with ASME Boiler and Pressure Vessel Code, Sect. VIII, latest edition. Also, all pressure vessels should be designed and constructed to satisfy applicable local and state codes for vessels (Ref. 5.12.1 and 5.12.2).

All other vessels should be designed and constructed in accordance with good engineering practice for the pressure and service in which they are to be used. Bottom openings and outlets should be avoided.

A minimum safety factor of 4 for vessels and vessel support material strength shall be maintained in all designs. Due allowance should be made for temperature, corrosion, and local seismic conditions.

5.3 Piping Systems

5.3.1 General

Information of a general and specific nature relating to pipe, pipe material, and piping installation is extensively covered in Ref. 5.12.3, 5.12.4, 5.12.5, and 5.12.6.

5.3.2 System Design

All piping used in the storage, venting, and transfer of propellants shall be designed in accordance with Sect. 3 and 6 of Ref. 5.12.3. Allowable tensile stresses for pipe materials are listed in Table 12 of Ref. 5.12.3. Material specifications for pipe, fittings, valves, flanges, tubing, and boltings are listed in Table 8 of Ref. 5.12.3.

In design of chlorine trifluoride piping systems, care should be taken to provide drainage and avoid traps so that system drainage is complete. Where trap conditions are unavoidable, drain plugs or valves should be provided. Provisions must be made to propelant-passivate the installed systems with gaseous fluorine (Sect. 8.5).

The accompanying chart (Fig. 6) for Flow of Chlorine Trifluoride in Schedule 40 Piping, are based upon graphical solution of

$$\Delta P = \frac{1.35 f S Q^2}{d^5}$$

where:

- ΔP = pressure drop in lb/sq in. per 100 ft of pipe
- f = friction factor (Fanning)
- S = specific gravity
- Q = flowrate in gal/min
- d = internal diameter of pipe in inches

5.3.3 Pipe and Fittings

Pipe and welding fittings are normally manufactured according to standard thickness and weight, as proposed by the American Standards Association. Adherence to these standards reduces unnecessary duplication in the manufacture of pipe and facilitates purchases in small lots. The standard schedules for stainless steel are given in Ref. 5.12.15. The schedule number of a pipe approximates the value of $1000 \times P/S$ to the nearest




Figure 5. Gallons per Minute vs Change in Pressure for Chlorine Trifluoride at 25 C




Figure 6 (Continued)

standard schedule number where P is the internal pressure and S is the allowable tensile stress of the pipe material in accordance with Table 12 of Ref. 5.12.3. The standard schedule numbers for pipe manufactured from alloys other than stainless steels are 40, 60, 80, 100, 120, 140, and 160. The standard schedules for stainless-steel pipe are 5S, 10S, 40S, and 80S. Other thicknesses in carbon and stainless-steel pipe are available on special order. Therefore, the nearest higher standard schedule to the required wall thickness is to be used.

Pipe wall thicknesses should be determined by the formula given in Ref. 5.12.3, Sect. 2, Chapt. 4, Para. 214 (-3).

$$t_m = \frac{P D}{2S + 0.8 P} + C \quad (1)$$

where:

- P = maximum allowable operating pressure, psig
- D = outside diameter, inches
- t_m = minimum pipe wall thickness, inches
- S = maximum allowable hoop stress, lb/sq in.
- C = allowance for mechanical strength, threading, and/or corrosion, inches

Note: Allowance should be made for temperature, shock, and corrosion as required.

A manufacturer's tolerance of 12.5 percent in wall thickness is to be considered when using the formula which can be obtained by multiplying the value of t by 0.875. As the ASA Code points

out, this method of solution is applicable to the so-called thin-walled pipe in which the pipe wall thickness, t , minus C (corrosion allowance in inches plus thread depth or groove depth) is less than one-sixth times the outside diameter. Where this ratio is exceeded, Para. 324 of Ref. 5.12.3 recommends the use of the Lamé formula plus the value, C , for determination of pipe wall thickness. The Lamé formula is:

$$\frac{D^2 + d^2}{D^2 - d^2} = \frac{S}{P} \quad (2)$$

where:

D = outside diameter, inches

S = allowable tensile stress per Table 12 of Ref. 5.12.3

P = design pressure, psi

A convenient form of the Lamé Formula is given in Para. UA-2 of Ref. 5.12.1 and is recommended for use with thick-walled pipe. The use of the Lamé Formula (Eq. 2) for thick-walled pipe results in a somewhat thinner wall than that obtained by the use of Eq. 1.

5.3.4 Pipe Hangers and Supports

Pipe supports, hangers, anchors, guides, and braces should be designed to prevent excessive stress, deflection, and motion in operation of the system, or too large a variation in loading with changes in temperature, and to guard against shock or resonance with imposed vibration and/or critical flow conditions.

Design and selection of the pipe supports should be in full accordance with Sect. 6, Chap. I, of Ref. 5.12.3. Additional information is included in Ref. 5.12.4, 5.12.5, 5.12.6, 5.12.10, 5.12.19 and 5.12.23.

5.3.5 Standard Flanges for Pipe

Tables are found in Ref. 5.12.1, 5.12.3, 5.12.4, 5.12.17, 5.12.18, and 5.12.19 showing the allowable working pressure ratings of pipe flanges at various operating temperatures.

ASA-B-16-5 flanges consist of seven pressure classes, each identified by the primary operating pressure: 150 lb, 300 lb, 400 lb, 600 lb, 900 lb, 1500 lb, and 2500 lb. These nominal pressure ratings are the ratings at an elevated temperature below which operating pressures higher than rated are allowable. Each pressure class contains a range of sizes and types. Within the same class, the allowable working pressure varies with the material and the operating temperature. Flange bolting materials should be in accordance with Ref. 5.12.3, Sect. 3, Para. 209.

Flanged connections should be utilized as follows:

1. All flange connections shall conform to ASA specifications (See Table 8, Ref. 5.12.3, Para. 5.3.3.)
2. For pressures below 300 psi (150 lb ASA), raised face flanges with serrated finish gasket faces should be used.
3. For pressures above 300 psi (to 2500 lb ASA), either tongue and groove or RTJ flanges should be used.

5.3.6 Expansion Joints and Flex Joints

Pipeline expansion joints and flex joints for chlorine trifluoride service shall be limited to the packless, bellows type. Where flow conditions permit, liners should not be used in the joints, as liners make proper cleaning and passivating difficult. Where it is economically feasible, it is always more desirable to design a piping system with the inherent flexibility of the pipe itself in the form of loops or bends to offset excessive thermal movement and resulting high stresses. Where this is impossible, bellows-type joints, designed in accordance with good engineering practice are recommended. Data are included in Ref. 5.12.5 and 5.12.12.

Particular care should be taken in design and installation of flex joints in chlorine trifluoride piping systems to avoid stress or alignment conditions which may cause failure; of prime concern is the positive elimination of all torsional stress. For pressurized use, the flex joints should be axially restrained. For flex motion in one plane, pinned-gimbaled joints are available. In design and selection of flex joints, allowance should be made for the extra forces involved in proof-pressure test operations, to avoid overstressing. Also, before pressurizing, the joints should be inspected for alignment and installed length; improper alignment, locked-in torsion, improper length, or improper restraint will cause short life and failure at lower than rated service.

5.4 Stainless-Steel Tubing and Fittings

All systems specifying stainless-steel tubing shall conform to MIL-T-8808A or MIL-T-8606A for Type 321 or Type 347 stainless,

or to MIL-T-8504 for Type 304 stainless. Fittings shall conform to AN or MS Standards for flared tube fittings. Various reports on stainless tubing and fitting applications point out inadequacies in commercial tubing (ASTM A213, ASTM A269) and commercial flared tube fittings. Broad tolerances in surface finish, dimensions, and other specifications prohibit their use for fabricating consistent leak-tight joints. Tube (AND) connections have been used with success, but are available only in sizes up to 2 inches.

5.5 Valves

5.5.1 General

The selection of valves for chlorine trifluoride service imposes certain design requirements more stringent or critical than with most other propellants. Of primary consideration is leak-proof capability and material compatibility. Most nonlubricated valve designs acceptable for use with other highly toxic and corrosive liquids may be used successfully with chlorine trifluoride if compatible materials are used. Leakage cannot be tolerated in valves used for chlorine trifluoride use. Soft metal seats (Al and copper) are used in place of plastic seats which are unsatisfactory. Valves should be tested to 300 psig minimum; and valves should be selected and designed so that any part of the exposed surfaces of nonmetallic gaskets and seals is no more than 0.002 to 0.003 inches removed from a metal heat conductor. Insofar as possible, the same metallic material should be used throughout the valve.

Valves used with chlorine trifluoride should be thoroughly cleaned and passivated, inspected, serviced, proof-pressure tested, and leak-tested prior to installation, propellant passivation, and use. Other factors in valve selection, particularly for propellant transfer use are: (1) action and response, (2) pressure loss (C_v factor), and (3) no particle migration of sealing material.

Fast and positive valve action is definitely required for use with high-energy propellants. The C_v factor is a measure of the pressure drop of the valve and is defined as "the number of gallons of water per minute which will flow through a certain valve within a pressure differential of 1 psig," (Ref. 5.12.21).

Particle migration is a problem whenever valve parts rub, turn, or wedge on plastic sealing materials. Migration can cause several problems in seal life and fouling close tolerance fits in ball valves, butterfly valves, and soft-seated gate valves.

The following valve types have been employed satisfactorily in chlorine trifluoride service, and their use (or equivalent) is recommended.

5.5.2 Needle Valves

Needle valves used for draining and purging should meet the same requirements as shutoff valves. Valves with O-ring or composition packing must be avoided. Teflon chevron packing is recommended for dynamic seals. Avoid lubricated valves and valves with lubricated surfaces exposed to the fluid. All valve materials must conform to those materials as specified in Sect.4, and all valves used should be capable of bubble-tight sealing. Metal-to-metal seats must be used (preferably with replaceable or renewable seats).

5.5.3 Shutoff Valves

5.5.3.1 General

For shutoff and transfer operations, the Globe valve should be used.

5.5.3.2 Globe Valves

These valves offer the optimum in service life and tight shut-off. Split-body type globe, or angle globe valves with metal-to-metal seat, and Teflon chevron packing (as manufactured by Annin or Pacific Valve companies, or equivalent) are recommended for general shutoff service. These valves are available in all-stainless steel and monel construction, in pressures up to 5000 psi, sizes up to 8 inches, and are supplied with any desired mode of valve operation; i.e., manual, air-operated, etc. Actuation systems of control valves should be "fail-safe."

5.5.3.3 Ball Valves

Ball valves are NOT recommended for chlorine trifluoride service due to undesirable sealing characteristics.

5.5.3.4 Gate and Butterfly Valves

Gate and butterfly valves should be avoided; these designs are not as durable, or else incorporate undesirable features such as poor sealing characteristics.

5.5.4 Check Valves

As with shutoff valves, a variety of designs exist which may be used in chlorine trifluoride service, depending upon system

requirements. For sizes up to 2 inches, the aircraft-type, or in-line poppet check valve of stainless-steel construction with metal seat is recommended. For metal-to-metal seating in the in-line type of check valve, the spring tension must be increased to provide positive seating. For swing check, ball or poppet types, the valves should also be spring-loaded to achieve positive shutoff and seating. Valves manufactured by Southwestern, Lanagan, or equivalent, have been used successfully. For systems above 2 inches, any of the high-quality industrial-type valves of the swing check, poppet, or ball check designs are acceptable when constructed of compatible metals and seat materials.

5.5.5 Valve Connections

Valve end connections are divided into four general types:

1. AND connections (flared type)
2. ASA flanged connections
3. Welded-type connections
4. NPT threaded connections

Because of servicing requirements of valving in place, type 3 should be avoided. Types 1 and 4 should be avoided in chlorine trifluoride systems because these connections cannot be cleaned and propellant-passivated reliably.

5.6 Relief Devices

Any high-quality relief valve with good relief-reseat characteristics and bubble-tight shutoff upon reseat may be used. Again,

such a valve should be of stainless steel or Monel construction with soft metal seats. Valves made by the Republic Manufacturing Company, Crosby, Anderson-Greenwood, or equivalent, are recommended for this service when provided with proper soft metal seating (Ref. 5.12.20). For use as an alternate relief device, rupture discs (burst discs) are recommended. These discs are available in a wide variety of sizes, alloys, and burst ratings; for extreme corrosion conditions, the discs may be plastic-coated or precious metal-clad. Discs require special safety-head flanges or holders, which are available in many materials and types.

Relief devices should be rated to burst at not more than 100 percent of the vessel or system rating when used as a primary relief device or 105 percent when used as a secondary relief device. The relief device must be sized to prevent the pressure from rising 10 percent above the maximum allowable working pressure.

5.7

Regulators

Regulators are used primarily to supply regulated nitrogen gas for transfer, purge, and control systems. The selection of regulators for service in chlorine trifluoride storage facilities depends upon its use. If a regulator is in a system which cannot be internally contaminated with chlorine trifluoride, no special requirements are necessary. When contamination is a possibility, the regulator material must conform to those specified in Section 4.0. Because regulator diaphragm material is not compatible with chlorine trifluoride, the diaphragm can be protected by covering the exposed surface with a thin sheet of

compatible plastic material. Regulators manufactured by Grove, Vector, Hoke, or equivalent have been used successfully.

5.8 Pumps

Pumps used in transferring chlorine trifluoride have not been developed to a point where they can be used reliably in a storage facility handling large quantities of the propellant. Until a reliable pump can be developed, it is recommended that transfer operations be conducted by means of a pressure-fed system.

5.9 Filters

Filters have an important role in chlorine trifluoride storage and transfer systems in maintaining propellant and inert gas cleanliness. Filters should be selected with woven wire mesh elements, fabricated of appropriate and compatible materials. The sintered-microsphere-type elements should be avoided due to difficulty in cleaning properly, and also since the microspheres become loosened in repeated cleaning operations and disintegrate. Pleated-type elements properly supported are preferred; they provide a smaller filter case for the same filter area.

The filter should be selected and located for easy and repeated opening and cleaning. The elements and case should be capable of supporting the full applied upstream pressure without damage because this condition can occur with a plugged filter.

Filters should be sized, rated, and selected for low pressure drop at the rated flows. Ten-psig differential pressure is the recommended maximum differential across a clean set of elements. The largest pore size recommended for use in liquid propellant operation is 20 microns nominal. Since the wires of the mesh are very fine and subject to damage and corrosion, ample spares should be provided in the initial procurement effort.

5.10 Air Pollution Monitoring

For use in monitoring air pollution in the vicinity of storage and transfer facilities using chlorine trifluoride, a system can be installed to sample the air and detect and record air pollution. Several types of commercial detectors are available for monitoring air for many and varied pollutants. It should be realized that because of fine sensitivity, some instruments will give erroneous readings due to air pollutants such as solvent vapors. For portable field use, leak detection units are available. The fixed type of monitor system should be installed with an alarm system.

5.11 Liquid Level Indicators

Liquid level indicators for propellant storage tanks must be selected of compatible materials and preferably of the same alloy as the tank and piping. If external tank sight gages are used, the gage valves should incorporate ball check valves for automatic liquid and vapor flow shutoff in case of gage breakage. Magnetic, float, and similar gages should be used in place of glass gages which will become cloudy when in contact with chlorine trifluoride.

5.12 References

- 5.12.1 ASME Boiler and Pressure Vessel Code, Section VIII, Rules for Construction of Unfired Pressure Vessels, latest edition.
- 5.12.2 Unfired Pressure Vessel Safety Orders, issued by the State of California, Department of Industrial Relations, Division of Industrial Safety.
- 5.12.3 American Standard Code for Pressure Piping ASA B31.1, 1955 Edition.
- 5.12.4 Piping Handbook by Sabin Crocker (McGraw-Hill).
- 5.12.5 Design of Piping Systems by M. W. Kellogg Co. (Wiley).
- 5.12.6 Industrial Piping by Charles T. Littleton (McGraw-Hill).
- 5.12.7 TubeTurns Bulletin TT700.
- 5.12.8 TubeTurns Bulletin TT726.
- 5.12.9 TubeTurns Bulletin TT640.
- 5.12.10 Piping Design and Engineering by the Grinnell Co.
- 5.12.11 Flow of Fluids through Valves, Fittings, and Pipe. Technical Paper No. 411 by the Crane Co.
- 5.12.12 Expansion Joint Standards by George P. Byrne, Jr., of the Expansion Joint Manufacturers Association.
- 5.12.13 Requirements of the American Petroleum Institute and the American Standards Association, including end connections and face-to-face dimensions.
- 5.12.14 American Standard for Wrought Steel and Wrought Iron Pipe ASA B36.10, latest revision.
- 5.12.15 American Standard for Stainless Steel Pipe ASA B36.19, latest revision.

- 5.12.16 American Standard for Pressure-Temperature Ratings of
Standard Steel Pipe Flanges ASA B16.5, latest revision.
- 5.12.17 Ladish Catalog No. 55.
- 5.12.18 TubeTurns Catalog No. 311.
- 5.12.19 Crane Co. Catalog No. 53.
- 5.12.20 How to Design a Pressure Relief System, by J. Connison,
Chem Eng - 25 July 1960.
- 5.12.21 Pacific Valve Co. Technical Paper #1060-2.
- 5.12.22 Pacific Valve Co. Technical Report #1060-3.
- 5.12.23 Grinnel Co. Catalog on Pipe Hangers and Supports

6.0 SYSTEM FABRICATION

6.1 General

Chlorine trifluoride storage and transfer systems are similar to those employed for handling ordinary fluids, except for materials of construction. Pump motors, solenoid valves, electrical switchgear, and other electrical equipment in the chlorine trifluoride transfer and storage systems should be selected and installed in accordance with the requirements of the National Electric Code, Article 500, Class 1, Division 2. All seals and joints in the propellant system should be periodically and frequently inspected for leaks and damage.

In the layout, placement, and arrangement of operating systems and units, ample spacing should be provided for proper maintenance clearances and adequate ventilation. In many cases, the removal, replacement, and servicing of valves, pumps, piping sections, instrumentation, and other equipment must be done by workers in protective clothing and wearing respiratory equipment. Ample room and access must be provided for use of tools and for easy movement of equipment. Where possible, equipment, valves, and lines should be located so that maintenance and service work can be accomplished from a position above the piping level to prevent propellant drips and leaks from falling on personnel.

6.2 Welding

6.2.1 General

The standards for welding pipe shall conform to Chapt. 4 of Ref. 6.6.1. Pipe fittings should be procured from reputable sources

who permanently mark their fittings as to: (1) manufacturer, (2) size and schedule of pipe, and (3) material and heat code. The fittings should be of the butt-welded type to facilitate system cleaning and purging operations. A typical set of standards for the acceptance of pipe welds is presented in Appendix 11.2.

The identity of each material used in the fabrication of propellant systems must be ensured. Test kits are available for the identification of metals in the field (Ref. 6.6.2).

6.2.2 Carbon Steel

Carbon steel piping and components are not recommended for service in chlorine trifluoride.

6.2.3 Stainless Steel

Fusion welding of stainless-steel pipe and fittings should be started with a root pass using the inert-gas-shielded tungsten arc method; helium or argon can be used as the inert gas. Subsequent passes may be made by the shielded metal-electrode method or by the inert-gas-shielded tungsten arc method. An inert gas (argon preferred) back purge should be maintained during the welding of stainless-steel pipe and fittings until the weld area metal temperature falls below 400 F. Shielded electrodes shall conform to MIL-E-6844 and welding rods to MIL-R-5031. Additional information on the welding of stainless-steel pipes and fittings can be found in Ref. 6.6.1, 6.6.3, 6.6.4, 6.6.5, 6.6.6, 6.6.7, and 6.6.8.

6.2.4 Aluminum

Since certain aluminum alloys can be used as pipe material for service in chlorine trifluoride, some discussion on the welding of this material is included. Fusion welding of aluminum pipe and fittings can be accomplished by the inert-gas-shielded tungsten arc method or by the shielded metal-electrode method. These welding methods require a back purge of inert gas. Detailed information on the welding of aluminum and aluminum alloys can be found in publications of the leading aluminum manufacturers (Kaiser, Reynolds, Alcoa, etc.).

6.2.5 Welding of Other Pipe Materials

The welding of other pipe materials compatible with the subject propellant can be found in Ref. 6.6.3 and 6.6.4.

6.3 Brazing and Soldering

Brazing and soldering techniques are not recommended for application in chlorine trifluoride systems. The joints produced by these methods are usually incompatible with the propellant.

6.4 Mechanical Joints

6.4.1 General

The advantages of a relatively leak-free, all-welded transfer system are obvious. From a practical standpoint, however, some type of joint, whether flanged or otherwise, is required to facilitate maintenance and to provide adequate system flexibility.

Small valves and components should be selected with AN flared-type connections. Large valves and components should be selected with flanged connections. Instrumentation connections should be of the AN type, and can be provided by welding boss fittings on large pipelines or by installing tee fittings on small lines.

6.4.2 Threaded Pipe Joints

Threaded pipe joints shall be avoided since these are a potential leakage source. In addition, localized corrosion may originate in this type of joint.

6.4.3 Flanged Pipe Joints

Flanged pipe joints are recommended whenever it is not practical to use welded joints. The flanges shall conform to ASA standards (Ref. 6.6.1, 6.6.9, and 6.6.10) for the welding neck type. Small tongue and groove, or raised-face flanges are preferred because most valves and pipeline components used in transfer systems can be furnished with these facings. A 1/8-inch-thick, full-face gasket of appropriate material is recommended for sealing the flanged joints. To assure minimum distortion in welding these flanges to piping, a heavy backup plate or mating flange must be installed during welding operations.

6.4.4 Tube Connections

Flared tube connections can be used in chlorine trifluoride systems. This type of joint is particularly suitable for instrumentation sensing line connections.

6.5 Inspection

6.5.1 General

In the construction, installation, and modification of chlorine trifluoride systems, inspection is important to assure quality of materials, adherence to design specifications, and proper fabrication techniques. Before installation, each piece of equipment, such as pumps, flex joints, valves, filters, etc., shall be inspected and tested for:

1. Cleanliness
2. Proper lubricants (if allowable)
3. Leakage, internal and external
4. Pressure-proof test
5. Sealant and gasket materials
6. Proper operation
7. Freedom from defects
8. Adherence to applicable specifications--type, size, rating, dimensions, etc.

Piping and tubing sections shall be inspected and tested for:

1. Conformance to design specifications and building codes
2. Identity and quality of materials of construction
3. Adequacy of supports; freedom from "cold spring"
4. Cleanliness

5. Proper fabrication workmanship
6. Proof-pressure and leak tests
7. Proper installation of flex joints

Electrical installations and equipment shall be inspected and tested for:

1. Conformance to design specifications and applicable codes
2. Adequate grounding
3. Insulation resistance
4. Circuitry continuity and proper termination
5. Workmanship and fabrication technique
6. Proper support of conduits and wiring

Instruments (flowmeters, gages, transducers, etc.) shall be shop tested, and calibrated and certified with due regard to using conditions, fluid density, operating range, material identity, repeatability, and sealing capability. These instruments must be inspected for cleanliness prior to installation.

Roads, buildings, structures, etc., should be inspected for conformance to design specifications and building codes.

6.5.2 Radiographic Inspection

Items fabricated from standard pipe and fittings ordinarily have a sufficient factor of safety that radiographic inspection is not

necessary. However, radiographic inspection may be required under the following conditions:

1. When noted on the governing drawing or specification; such is the case when it becomes necessary to obtain high weld efficiencies
2. When welds are visually suspicious; such as the case when the welder or the inspector doubts the soundness of the weld
3. When items are fabricated from nonstandard piping or fittings

Critical areas such as primary structures and anchor weldments, whose failure would result in installation or anchor collapse, shall be thoroughly analyzed by the designer and radiographic inspection specified, if required.

Radiographic inspection shall be specified only when it is beneficial. This type of inspection is not applicable to all weld types, and is a relatively costly process. Properly designed piping systems, welded by a certified welder and visually inspected by a qualified inspector, normally do not require radiographic inspection.

6.6 References

- 6.6.1 "American Standard Code for Pressure Piping, ASA B31.1," latest edition.
- 6.6.2 "Rapid Identification (Spot Testing) of Some Metals and Alloys," International Nickel Company.

- 6.6.3 Commercial Publications by Carpenter and Patterson, Inc.,
Cambridge, Mass.
- 6.6.4 "Welding Handbook," American Welding Society.
- 6.6.5 "Fabrication of USS Stainless Steel," United States Steel Corp.
- 6.6.6 "Stainless Steel Fabrication," Allegheny-Ludlum Corp., Pitts-
burgh, Pa.
- 6.6.7 Stainless Steel Fittings Catalog, Ladish Co., Cudahy, Wisc.
- 6.6.8 Stainless Steel Fittings Catalog, TubeTurns.
- 6.6.9 "American Standard for Pressure-Temperature Ratings of Stand-
ard Steel Piping Flanges," ASA B16.5, latest edition.
- 6.6.10 "Piping Handbook," by Sabin Crocker, McGraw Hill.

7.0 HYDROSTATIC AND/OR PNEUMATIC TESTS

7.1 Storage Vessels

Vessels certified by an ASME inspector and/or state safety order code inspector need not be tested. Vessels that are exempt from or vary from the ASME code shall be tested in conformance with ASME code requirements. Vessels that have been damaged because of fire, fragmentation, etc., or that have been reworked or repaired, must be re-inspected and recertified for use.

7.1.1 Hydrostatic Test

The hydrostatic test shall in no case be to less than 1-1/2 times the maximum allowable working pressure which is to be stamped on the vessel. No upper limit is set on the hydrostat; however, if the pressure is allowed to exceed (intentionally or accidentally) 1-1/2 times the maximum allowable pressure to the extent that the vessel is distorted, the inspector will reserve the right to reject the vessel. The test pressure shall be held for a sufficient time to permit an inspection to be made of all joints and connections.

Vessels that require hammer tests shall be tested while the hydrostatic pressure is between 1-1/4 and 1-1/2 times the maximum pressure.

7.1.2 Pneumatic Tests in Lieu of Hydrostatic Test

Vessels and attached systems shall undergo pneumatic tests in lieu of hydrostatic test under the following conditions.

1. When the vessels and attached systems are so designed and/or supported that they cannot safely be filled with water
2. Those to be used in service where traces of the testing liquid cannot be tolerated
3. Those systems where the parts have been previously hydrostatically tested to $1\frac{1}{2}$ times the maximum working pressure of the vessel

The pneumatic test pressure shall be at least $1\frac{1}{4}$ times the maximum allowable pressure.

Welded vessels shall be hammer tested prior to the pneumatic test.

Caution. All personnel shall be evacuated from the area until after a test has been conducted to a pressure of $1\frac{1}{4}$ times the maximum operating pressure and the pressure has been reduced to the maximum operating pressure or less for vessel inspection.

The test pressure in the vessel shall be increased gradually to not more than $\frac{1}{2}$ the test pressure. Thereafter, the pressure shall be increased in increments of approximately $\frac{1}{10}$ of the test pressure until test pressure has been reached. The pressure shall then be reduced to a value equal to the maximum allowable pressure and held for a sufficient time to allow inspection of the vessel. Failure, leakage, distress, or permanent distortion shall be sufficient cause for rejection.

7.2 Valves, Piping, and Fittings

7.2.1 Hydrostatic Test Before Installation

Every valve, filter, check valve, flex joint, etc., shall withstand an internal hydrostatic proof pressure for which the manufacturer guarantees it, without leakage, failure or permanent deformation.

Each prefabricated or spooled pipe section, manifold, and special fitting shall be inspected and tested in accordance with Ref. 7.3.2, Sect. 3, Para. 322 and 323. In case of leakage, deformation or failure, the piping shall be properly repaired and retested.

The hydrostatic test shall be conducted with either water or hydraulic oil as the test media. Only those components to be utilized in hydraulic oil or kerosene-type-fuel systems may be proof tested with hydraulic oil.

7.2.2 Hydrostatic Test After Installation

After the system is installed and secured, it shall be pressure tested in accordance with Ref. 7.3.2, Sect. 3, Para. 323. In case of leakage, damage, failure, or deformation, the piping shall be properly repaired and retested.

7.2.3 Pneumatic Test in Lieu of Hydrostatic Test

A pneumatic proof test shall be conducted ONLY when water will damage parts or when the presence of minute amounts of water cannot be tolerated, and the configuration of the system prevents a guarantee of dryness.

The pneumatic proof test is allowable ONLY AFTER prior hydrostatic proof test of subassemblies and components to 1-1/2 times the maximum operating pressure. Test fluid should be clean, filtered, dry, hydrocarbon-free nitrogen gas or air.

The pressure shall be increased slowly to 1-1/2 times the maximum allowable operating pressure, and be locked and held for five minutes. If the pressure gage indicates a drop in pressure, the pressure shall be relieved, the cause of leakage or creep corrected, and the test repeated.

Caution. Personnel shall not enter the area until after a test has been conducted to a pressure of 1-1/2 times the maximum operating pressure and the pressure has been reduced to the maximum operating pressure, or less, for inspection.

Failure, leakage, distress, or distortion (other than elastic distortion) shall be sufficient cause for rejection.

7.3 Applicable Codes and Specifications

7.3.1 ASME Boiler and Pressure Vessel Code, Section VIII, Rules for Construction of Unfired Pressure Vessels, latest edition.

7.3.2 American Standard Code for Pressure Piping ASA B31.1, latest edition.

8.0 CLEANING PROCEDURES

8.1 General

This section outlines the chemical cleaning procedures to be employed to remove oxides, scale, dirt, weld, and heat-treat slag, oil, grease, and foreign material from storage facility equipment. Items previously cleaned and passivated per this section, and which have not been machined, welded, heated, or otherwise contaminated or oxidized, may be prepared for service by degreasing. Basically, items such as valves, pumps, actuators, etc., cannot be cleaned in the assembled state since solvents may be trapped in inaccessible areas. Therefore, cleaning should be done immediately before assembly, or cleaned parts should be packaged to protect against recontamination until ready for assembly.

All cleaning, passivating, and rinse solutions should be applied by immersing, spraying, wiping, circulating, or other manner so that ALL surfaces to be cleaned will be completely wetted and flushed with the solutions. Any section of the item to be cleaned that can trap or retain any liquid should be drained or emptied between the applications of each different solution of chemical mixture. The item should be rinsed until it is chemically neutral between each operation. Do not allow surfaces to dry off between cleaning and passivation steps. The water used should be distilled, deionized, or clean tap water, filtered through a 40-micron nominal filter. Unless otherwise specified, all chemicals should be C.P. (chemically pure) grade or better.

8.2 Degreasing

8.2.1 Metal Parts

All metal parts should be degreased by cold-flushing with high-purity, low stabilized trichloroethylene, vapor degreased with trichloroethylene which meets MIL-T-7003 Specification, or flushed with a mild alkaline solution (5 to 7 ounce/gallon) at 140 F to 160 F, such as Turco No. 4090 or equivalent. If used, the mild alkaline cleaner must be followed by a water rinse to remove all traces of cleansing compound.

Large parts, whose size or configuration prevent vapor degreasing or cold-flushing in a spray booth, should be degreased by spraying or hand-wiping with high-purity, low stabilized trichloroethylene or with a mild alkaline cleaning solution such as Turco #4090 or equivalent. Degreasing agents used for hand-wiping, brushing or in a spray booth shall not be reused.

8.2.2 Nonmetal Parts

Nonmetallic and bonded nonmetallic parts such as gaskets, O-rings, chevron rings, hoses, etc., should be degreased by immersion or scrubbing at 140 to 160 F, with the mild alkaline solution (5 to 7 ounce/gallon) mentioned above, or equivalent, followed by rinsing with water. Teflon, polyethylene, Kel-F, or Viton, except when bonded to metal, may be cleaned with trichloroethylene. Items which have solvent or water remaining on their surface and are not to be further chemically cleaned, shall be dried.

8.3 Descaling or Cleaning

8.3.1 General

Newly fabricated or reworked parts which have scale from welding, heat treatment, or impurities from casting or forging, should be descaled. Descaling solutions should not be used after finish-machining of precision surfaces without protection or on parts that do not have heavy oxide or foreign material buildups in the form of rust or scale. The contact time of the descaling solution and the item to be cleaned should be the minimum time necessary to clean the part or the maximum allowable time per this section, whichever is shorter. Only plastic-coated or nonmetallic gaskets should be used with nitric-hydrofluoric descaling baths, to prevent excessive metal loss caused by electrolytic corrosion.

8.3.2 Stainless Steel

1. Etch for a minimum period, and not longer than sixty minutes, at room temperature (60 to 80 F) with a mixture of 3 to 5 percent technical grade hydrofluoric acid (by weight), and 15 to 20 percent technical grade nitric acid (by weight), and the remainder water.

2. Rinse with water to remove all traces of descaling solutions. Loosely adhering smut or flux may be removed by spraying with water or scrubbing with stainless steel or hemp brush. If the parts are to be immediately passivated after acid cleaning, they need not be dried. The parts may be dried completely by purging with dry, hydrocarbon-free nitrogen or air, or in an oven at 140 to 150 F. The AISI 400 series, 303S, and 303SE shall be descaled by mechanical methods such as machining, abrasive tumbling, or grit blasting.

8.3.3 Aluminum and Aluminum Alloys

1. Clean with a chromic acid cleaner (5 to 7 oz of Turco Smut-Go or equivalent cleaner per gallon of water), at 100 F, until the surfaces are visibly clean and shiny.
2. Rinse with water to remove all traces of the acid solution.

8.4 Passivation

8.4.1 General

All corrosion-resistant steel, except nonwelded tubing assemblies, shall be passivated after descaling or final machining. All metals used should be cleaned and passivated before use and maintained in a clean, dry condition until installed.

Acid passivation of materials with highly polished or lapped surfaces may be eliminated if the polished or lapped surfaces cannot conveniently be protected from the acid solution.

8.4.2 Stainless Steel

1. Immerse in a solution of 45 to 55 percent technical grade nitric acid (by weight) with the remainder water, at 60 to 80 F, for a minimum period of thirty minutes.
2. Rinse and flush thoroughly with water to remove all traces of the passivating solution.
3. Drain and dry by purging with dry, filtered, hydrocarbon-free nitrogen or air, or dry in an oven at 140 to 150 F.

The nitric acid passivation solution should be used for the AISI 300 and 400 series stainless steel. The protective film resulting from this passivation process will not normally be visible, but surfaces shall be uniform in appearance, free from scale, corrosion, pitting, and contaminants. Normal discoloration from welding will be permitted, provided no scale or rust is associated with the discoloration.

8.4.3 Aluminum and Aluminum Alloys

1. Passivate with a solution of 45 percent technical grade nitric acid (by weight) at room temperature for a minimum period of one hour.
2. Rinse and flush with water to remove all traces of nitric acid.
3. Drain and dry by purging with dry, filtered, hydrocarbon-free nitrogen or air, or dry in an oven at 140 to 150 F.

Machined aluminum barstock parts do not normally require descaling or passivating processes and can be prepared for service by degreasing. Welded, cast, or corroded parts will require descaling, cleaning, and passivating. Anodized aluminum parts shall not be descaled or passivated and should be prepared for service by degreasing.

8.5 Propellant Passivation

After cleaning (per the chemical cleaning procedures) and installation, the system MUST be propellant-passivated before introduction of chlorine trifluoride according to the following procedure:

1. All components of the system must be assembled in a dry and clean condition.

2. Evacuate the system by means of a high-capacity vacuum pump for at least two hours.
3. Place a slight positive pressure in the system using dry, hydrocarbon clean nitrogen, and remove the vacuum pump.
4. Fill the system with gaseous fluorine until a pressure of 10 to 25 psig is obtained. After the fluorine has been in the system for about 10 minutes, bleed the system slowly until ambient pressure is reached.
5. Fill the system with gaseous fluorine to 100 psig or the maximum allowable working pressure if less than 100 psig. After the fluorine has been in the system under pressure for 30 minutes, bleed the system slowly until ambient pressure is reached.

Precautions must be taken to prevent the entry of moisture into the system. Moisture will react with the metal fluoride coating causing it to hydrolyze and consequently become very brittle. After hydrolysis has taken place, mechanical shock will cause separation of the coating and expose unpassivated surfaces to chlorine trifluoride. The hydrolyzed fluorides will also pass through the system in particulate form, and cause further contamination due to plugging.

The above procedure provides slow, controlled burnout of any contaminants and a slow buildup of the protective fluoride film.

8.6 Drying and Handling

8.6.1 Drying

Items which have solvent or water remaining on their surfaces and which are not to be further chemically cleaned, should be dried by flushing with dry, hydrocarbon-free, filtered nitrogen gas or air, or by heating to 140 to 150 F.

8.6.2 Handling

Items that have been cleaned should be handled, stored, or packaged in a manner to prevent recontamination.

Immediately following cleaning and passivation, large valves, piping sections, vessels, flex joints, subassemblies, and other prefabricated items should be dried and have ends and openings capped, plugged, or flanged and sealed with clean compatible sealing material. Small valves and components should be purged with clean, dry gaseous nitrogen and wrapped and sealed in clean plastic bags. These components should be kept sealed until installation.

8.7 Inspection

8.7.1 General

All parts may be inspected for cleanliness by one or more of the following inspection techniques.

8.7.2 Visual Inspection

Parts should be inspected for rust, scale, dirt, chips, or grease, or other foreign material. The presence of such deposits will necessitate recleaning of the part. Light discolorations due to welding and passivation will be permitted providing no scale or rust is associated with the discoloration.

8.7.3 Water Break Test

The water break test is not a valid indication of cleanliness under the requirements and conditions of this section.

8.7.4 Soiling Test

After lightly wiping with a clean, lint-free, white cloth, no visible deposit shall occur on the cloth. Discoloration may occur with metals such as aluminum if the surface is rubbed hard enough to abrade the surface. Discoloration from this abrasion can be confused with dirt.

8.7.5 Ultraviolet Light (Black Light)

Inspection under ultraviolet light will cause some oils and greases to fluoresce. This procedure will not detect vegetable- or animal-type oils and greases, RP-1, JP-5, NA2-20502 (liquid oxygen-safe), toluene, DC-11, Fluorolube, or MIL-0-5606. This test is not valid on serviced components without further identification of the fluorescent material because some acceptable lubricants fluoresce.

8.8 Material Reference

8.8.1 Turco Smut-Go: Chromic acid-type cleaner furnished by the Turco Products, Inc., 6135 South Central Avenue, Los Angeles, California.

8.8.2 Mild Alkaline Cleaner: Detergent-type cleaner similar to Turco No. 4090, furnished by Turco Products, Inc.

9.0 INSPECTION AND MAINTENANCE

9.1 General

A periodic inspection to determine the current and projected maintenance requirements should be made. This should take into consideration the frequency of use, reliability, environment, stresses, and other special conditions which may arise.

When performing inspection and maintenance operations, all safety precaution must be taken prior to entering vessels or systems used with chlorine trifluoride.

9.2 Inspection

9.2.1 Coded Vessels

All ASME Coded Vessels should be externally inspected by a qualified inspector at least once a year. An internal inspection shall be made whenever the head of the vessel is removed, or when the corrosion rate dictates.

9.2.2 Noncoded Vessels

All Noncoded Vessels should be externally inspected by a qualified inspector at least once every six months. An internal inspection should be made whenever the head of the vessel is removed, or when the corrosion rate dictates. Based upon this inspection, a hydrostatic test may be required before use of the vessel is resumed.

9.2.3 ICC Vessels

All vessels that are ICC-Coded, in addition to periodic inspections as described for other vessels (see above), shall be inspected and tested for conformance with ICC Code at least once every five years. All attendant systems should be periodically checked by a qualified inspector at least once every six months for leaks, potential failures, etc. Proof tests should be conducted to verify the safety of a system as deemed necessary by the inspector or responsible storage area personnel.

9.2.4 Vessel and Pipe Systems

Storage vessels and pipe systems should be checked at least once each six months for signs of settling, misalignment, tightness of connections, signs of leaks and corrosion. Settling can strain and rupture piping.

9.2.5 Safety Equipment

The water fog or spray system should be checked for flowrate, pattern, and operation at least once each week.

All safety showers and eyebaths should be inspected and tested for flowrate, pattern, and operation on a biweekly basis or prior to any chlorine trifluoride handling operation.

Personnel protection equipment (clothing, respiratory equipment, etc.) should be checked for availability and condition at least once a week or prior to any chlorine trifluoride handling operation.

9.2.6 Propellant Transfer Equipment

The equipment should be checked for proper operation on a bi-monthly basis or by the operating personnel during each chlorine trifluoride handling operation.

9.3 Maintenance

9.3.1 Valves and Pumps

Valves and pumps should be serviced when the operation of the item becomes erratic or a leak develops. Schedules can be established based upon expected service life for preventative maintenance.

9.3.2 Instrumentation Equipment

Instrumentation equipment should be serviced at least once each six months.

9.3.3 Filters

Filters should be serviced when the differential at rated flow conditions exceeds 15 psig, or as specified in the manufacturer's service instructions.

9.3.4 Relief Devices

Rupture disks (burst disks) should be replaced at least once each four months.

Relief valves should be serviced at least once each six months.

9.3.5 Safety Equipment

Water fog or spray system, safety showers, and eye baths should be serviced at least once each four months.

Personnel protection equipment should be serviced at least once each month.

9.3.6 General Storage Area

The general storage area should be constantly maintained to good safety and housekeeping standards. Some of these maintenance operations are:

1. Removal of obstacles from roads, paths, and stairs
2. Removal of combustible materials from the storage area
3. Prevention of oxidation of equipment, piping, vessel etc.
4. Properly storing handling tools and equipment
5. Maintaining clean revetments, channels, basins, and sumps.

10.0 REACTIVATION OF EXISTING FACILITIES

10.1 Design Evaluation

The design of existing facilities which are to be reactivated for use with chlorine trifluoride should be thoroughly evaluated with special attention to the following:

1. Allowable working pressures
2. Relief systems
3. Flowrates and pressure drops
4. Means of transfer
5. Systems configuration
6. Sealing characteristics
7. Supports, hangers, bracing, and brackets
8. Maintenance clearances
9. Compatibility of materials of construction
10. Safety

10.2 Inspection of Usable Components

The components to be used should be dismantled and inspected for corrosion, deformities, etc. If the components are unable to meet the standards established in Part III, they should be discarded. The identity of materials of construction can be verified by use of chemical spot tests ("Rapid Identification of Metals and Alloys," by International Nickel Co.).

10.3 Rework and/or Cleaning of Usable Components

Vessels, piping, valves, and other components to be used should be reworked and/or cleaned as follows:

1. Vessels shall be reworked and cleaned in accordance with sections 5.2.7.1 and 8.0.

2. Piping shall be reworked, cleaned and installed in accordance with Sections 5.3, 7.2 and 8.0.
3. Valves, flexjoints, pumps, check valves, etc., shall be reworked and cleaned in accordance with Sections 4.0, 5.0, 7.2, and 8.0

11.0 APPENDICES

11.1 Water Storage Capacity

The amount of water required for controlling chlorine trifluoride fires in the storage area can be determined by the following relation:

$$5.0 V_1 + x V_2 + 10,000 = C$$

where:

V_1 = Capacity of largest single chlorine trifluoride storage tank, gal

V_2 = Total chlorine trifluoride storage capacity, gal

x = A function which can be expressed as:

2.0 for V_2 from 100 to 15,000 gal

1.8 for V_2 from 15,000 to 50,000 gal

1.7 for V_2 above 50,000 gal

C = Water storage capacity required for fire control, gal

Satisfactory storage tank cooling can be obtained by applying water at a rate of 0.30 gpm per square foot of external tank surface.

11.2 Acceptance Standards for Welds

A typical set of acceptance standards for welds is as follows:

1. Cracks of any nature, whether crater, underbead, transverse, longitudinal or parent metal will be rejected.

2. Crater cracks which are determined to be only surface defects may be removed by machining or grinding. They need not be rewelded provided buildup is not less than 10 percent nor more than 30 percent of the metal thickness, nor if drop-through is not less than flush nor more than 30 percent of the metal thickness.
3. Normally acceptable defects occurring in conjunction with or adjacent to cracks will be rejected for a distance of two inches each way from the crack.
4. Butt joints shall have 100 percent penetration throughout 100 percent of the linear length of the weld.
5. Any lack of fusion will not be accepted.
6. Undercut, excessive drop-through and excessive roughness shall be cause for rejection. Folds in drop-through will be accepted if they are not greater in depth than 10 percent of the thickness of the parent metal.
7. Porosity or inclusions occurring in the weld metal, exclusive of the weld reinforcements in which any radiographic image is darker than the parent metal or larger in its greatest dimension than 15 percent of the parent metal thickness will be rejected.
8. Porosity and inclusions in the weld reinforcement will be acceptable provided they do not extend through the surface of the reinforcements and provided they do not result in an objectionable stress riser.
9. Porosity and inclusions whose greatest dimensions are equal to or less than 15 percent of the parent metal

thickness will be acceptable to the extent of one pore per inch of weld length.

10. Tungsten inclusions located in the penetration zone will be accepted provided the greatest dimension of any particle is not over 25 percent of the parent metal thickness.

11.3 Specifications Criteria for the Design and Fabrication of Facility Installations

The design, fabrication, and/or modification of the propellant storage area must be accompanied by a design and construction specification. This specification should include the following:

1. List of applicable drawings and specifications
2. Work schedule
3. Description and scope of work, and location
4. Materials of construction
5. Inspection and test requirements

The technical portion of the specification may be sectionalized as follows:

1. Civil and structural
2. Electrical
3. Mechanical

Each section should be detailed and complete in itself and should include:

1. Material and workmanship

2. Specifications and standards
3. Allowable tolerances
4. Inspection requirements
5. Finish requirements
6. Definition of technical terms

The civil and structural section should include the following:

1. Buildings and structures
2. Concrete work
3. Area preparation, grading, and roads
4. Drainage system
5. Burn and collection basins
6. Reclamation sump
7. Inspection

The electrical section should include the following:

1. Power and lighting distribution
2. Transformers and switches distribution
3. Grounding, bonding, and lightning protection
4. Communications and warning systems
5. Electrical remote controls
6. Testing and inspection
7. Electrical instrumentation

The mechanical section should include the following:

1. Vessels and storage tanks
2. Piping and components lists and classification
3. Anchors and supports
4. Mechanical and pneumatic instrumentation
5. Welding of piping, vessels, etc.
6. Cleaning of tanks, piping, and components
7. Location and distribution of area safety equipment
8. Inspection and testing, including any performance tests

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D.J. Hatz. September 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p> <p>(over)</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
--	--

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D.J. Hatz. September 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p> <p>(over)</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
--	--

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D.J. Hatz. September 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p> <p>(over)</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
--	--

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D. J. Hatz. September, 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p> <p>(over)</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
--	--

<p>AD-</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez-Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
---	---

<p>AD-</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez-Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
---	---

<p>AD</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez-Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
--	---

<p>AD-</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez-Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
---	---

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D.J. Hatz. September 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Unclassified report</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
---	--

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D.J. Hatz. September 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Unclassified report</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
---	--

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D.J. Hatz. September 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Unclassified report</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
---	--

<p>AD-</p> <p>Rocketdyne, a Division of North American Aviation, Inc., Canoga Park, California MECHANICAL SYSTEM DESIGN-CRITERIA MANUAL FOR CHLORINE TRIFLUORIDE by E. Suarez-Alfonso, A.E. Chambers, and D. J. Hatz. September, 1961, 79 p incl. illus. (Proj. 3148, Task 30196) (AF/SSD-TR-61-4) (Contract AF 33(616)-6939)</p> <p>Unclassified report</p> <p>Presents criteria for the design and fabrication of a ClF₃ storage facility. Consideration is given to the integrity of the storage system and personnel safety.</p>	<p>UNCLASSIFIED</p> <ol style="list-style-type: none"> 1. Chlorine trifluoride 2. Design of liquid propellant storage facilities 3. Selection of materials and components for use with liquid propellants <p>UNCLASSIFIED</p>
---	--

<p>AD-</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez- Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
---	--

<p>AD-</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez- Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
---	--

<p>AD</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez- Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
--	--

<p>AD-</p> <p>The properties of ClF₃ affecting the selection, design and fabrication of storage facilities and the selection of compatible materials of construction and control equipment are discussed. Procedures for testing, cleaning, and inspecting the storage system, or components thereof, are reported. In addition, the reactivation of existing facilities for use with ClF₃ are discussed.</p>	<p>UNCLASSIFIED</p> <p>I. Suarez- Alfonso, E. II. Chambers, A.E. III. Hatz, D.J.</p> <p>UNCLASSIFIED</p>
---	--

UNCLASSIFIED

UNCLASSIFIED